

## Jack Krill

---

**Subject:** FW: Request for Comment L-96-S-257G

---

**From:** Jack Krill  
**Sent:** Friday, July 31, 2009 8:39 AM  
**To:** 'Jim Brady'  
**Cc:** 'Dennis Scott'; 'Norma Jean Knowles'; 'Chan'; Penney Laird  
**Subject:** RE: Request for Comment L-96-S-257G

Jim:

The Timberlake Fire Protection District has reviewed the application to move Fran's Floating Restaurant from Harborview to JD's F-Dock. We have no objection to the actual building being relocated, however we do have serious concerns with operating a restaurant (a public assembly-type occupancy) at the end of F-Dock due to the lack of fire protection measures on F-dock and the lack of adequate egress from Lakeside Avenue to F-dock. Additionally, I will not authorize a restaurant to operate more than 150 feet from the nearest fire apparatus access (parking area) unless the building meets current fire code requirements, has a monitored fire alarm system, and unless fire protection measures are fully implemented on that specific dock as required in the attached notices. If the building is going to operate as something other than a restaurant, we would have to conduct a fire code review based on the planned type of operation and occupancy type.

Thanks, Jack Krill

### Jack Krill, Fire Chief

Timberlake Fire Protection District  
5985 E. Highway 54, PO Box 810, Athol, ID 83801  
208-683-3333, Fax 208-683-6002, Cell 208-818-1101  
[jkrill@timberlakefire.com](mailto:jkrill@timberlakefire.com), [www.timberlakefire.com](http://www.timberlakefire.com)

---

**From:** Jim Brady [mailto:jbrady@idl.idaho.gov]  
**Sent:** Wednesday, July 29, 2009 3:51 PM  
**To:** Jim Brady  
**Cc:** Dennis Scott  
**Subject:** Request for Comment L-96-S-257G

All, attached a a request for comment on an application to move a floating restaurant from one marina to another. Thanks, have a good day and stay cool.

Jim Brady, Lands Resource Specialist Sr.-  
Minerals and Navigable Waters  
Idaho Department of Lands  
2550 Highway 2 West  
Sandpoint Idaho 83864  
(208) 263-5104 (208) 263-0724 fax