



## **Timberlake Fire Protection District**

P.O. Box 810 • 5985 E. Highway 54 • Athol, ID 83801  
Telephone: 208-683-3333 • Fax: 208-683-6001  
chief@timberlakefire.com • www.timberlakefire.com

**October 26, 2008**

**Mr. Jim Brady, Resource Specialist, Sr.**

Navigable Waters & Minerals  
Idaho Department of Lands  
Pend Oreille Supervisory Area  
2550 Highway 2 West  
Sandpoint, ID 83864

**Subject: Response to Application L-96-S-116I – Waterford Park Homes, LLC, Boileau's Marina**

Dear Mr. Brady:

In response to your September 29, 2008 letter regarding Application L-96-S-116I, the Timberlake Fire Protection District (TFPD) has the following comments and questions:

1. Who will be responsible for fire code compliance in the marina, including the "Limited Common Areas?" There are currently fire code issues that need to be addressed such as fire extinguishers, standpipes, and a means to notify the fire department rapidly in the event of an emergency (as identified in the September 22, 2008 letter submitted).
2. In a preliminary survey of the marina in question, the electrical shut offs to the structures are not clearly marked. In the event of a fire in the marina, power must be secured before fire attack can begin. Without clear indications or labels on the power meters and main circuit breakers, fire department operations will be delayed.
3. Address numbers or building numbers, per the Idaho Fire Code, are not present on many of the structures in the marina. Proper building identification must be in place and a map showing building numbers must be submitted to the fire department.

Respectfully,

/s/

Jack Krill, Fire Chief