



## Timberlake Fire Protection District

P.O. Box 810 • 5985 E. Highway 54 • Athol, ID 83801  
Telephone: 208-683-3333 • Fax: 208-683-6001  
chief@timberlakefire.com • www.timberlakefire.com

September 22, 2008

**Mr. Jim Brady, Resource Specialist, Sr.**

Navigable Waters & Minerals  
Idaho Department of Lands  
Pend Oreille Supervisory Area  
2550 Highway 2 West  
Sandpoint, ID 83864

**Subject: Response to Application L-96-S-116H – Waterford Park Homes, LLC, Boileau's Marina**

Dear Mr. Brady:

In response to your September 8, 2008 letter regarding Application L-96-S-116H, the Timberlake Fire Protection District (TFPD) requires the following:

- Waterford Park Homes must submit a TFPD building permit for the project.
- Prior to any modification or additions to the marinas, the following fire code requirements must be met:
  - Idaho Fire Code 2006 Edition, Section 905.3.7 and the International Fire Code 2006 Edition, Section 905.3.7. Both codes state: *Marinas and boatyards. Marinas and boatyards shall be equipped throughout with standpipe systems in accordance with NFPA 303 (National Fire Protection Association Standard 303, Fire Protection Standard for Marinas and Boatyards, 2006 Edition).*
    - Class I standpipe systems shall be provided for piers, bulkheads, and buildings where the hose lay distance from the fire apparatus exceeds 150 ft.
  - Fire extinguishers listed for Class A, Class B, and Class C fires shall be installed at the pier/land intersection on a pier that exceeds 25 ft in length. Additional fire extinguishers shall be placed such that the maximum travel distance to an extinguisher does not exceed 75 ft (IFC 906.2, NFPA 303, and NFPA 10).
  - All marinas shall have a means to notify the fire department rapidly in the event of an emergency (NFPA 303).

Respectfully,

/s/

Jack Krill, Fire Chief